AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

TEST REPORT

Client: Aspecta Apac Pty Ltd

9/337 Bay Road Cheltenham VIC 3192 **Test Number** : 22-003082

Issue Date : 19/09/2022 Print Date : 4/10/2022

Sample Description Clients Ref: "Aspecta Loose Lay, Elemental Loose Lay"

Luxury Vinyl Tile

Colour : Timber look End Use : Flooring

Nominal Composition: PVC, filler, Pigments

Nominal Thickness: 5mm



279608 59885 Page 1 of 2

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



ICHAFL A. JACKSON B.Sc.(Hons)

Fiona McDonald

APPROVED SIGNATORY



Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

TEST REPORT

Client: Aspecta Apac Pty Ltd

9/337 Bay Road Cheltenham VIC 3192 Test Number : 22-003082 **Issue Date** 19/09/2022

Print Date 4/10/2022

ISO 9239.1:2010 Part 1

Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a **Radiant Heat Source**

Date of Sample Arrival

10-08-2022

Date Tested

16-08-2022

CHF Value	1	2	3	Mean
Length	9.2	9.4	9.6	9.4 kW/m²
Width	10.6	-	-	- kW/m²
Smoke Value	1	2	3	Mean
Length	132	75	95	101 %.min
Width	64	-	-	- %.min

Observations

Blistering Yes

Each specimen was clamped to a substrate of 6mm thick fibre reinforced cement board prior to testing.

HF30 not reported as flame out time occurred before 30 minutes.

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Results in accordance with section 9.4 have not been included in the report. They are available upon request.

279608

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved

59885

Page 2 of 2



Accredited for compliance with ISO/IEC 17025 - Testing Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

A. JACKSON B.Sc.(Hons) ANAGING DIRECTOR

Fiona McDonald APPROVED SIGNATORY

0204/11/06