

VOC Content Test Certificate

Friday 3rd November 2023

Supplier: Jacobsen Creative Surfaces Ltd (41D Morrin Road, St Johns, Auckland 1072, New Zealand).

Product name: J-System 32 Fine Finish Compound

Date Tested: October 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification New Zealand Green Building Council Green Star Design & As Built V1.1-13.1.1B Green Star Interiors V1.1-12.1.1B	J-System 32 Fine Finish Compound
Primers, Sealers and Prep Coats Limit: 65 grams per litre	<1 gram per litre as VOC content per material
<i>We hereby certify J-System 32 Fine Finish Compound is below the VOC Content limits of chosen category specified by Green Star Interiors, Green Star Design & As Built, New Zealand Green Building Council.</i>	

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant

Travis Hale
BSc (Biotechnology)
Senior Consultant