

Slip Check to AS 4586:2013

Art Select Oak Premier

NATA Accreditation Number 17139

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Accredited for compliance with ISO/IEC 17025

NATA is a signatory to the APLAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration and inspection reports

28 June 2016

Test Report No. M0192g

Slip Resistance Classification of New Pedestrian Surface Materials

AS 4586:2013 Appendix A (Wet Pendulum Test)

The slip resistance Classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface.

Requested by: Karndean Designflooring
Client Address: 835 Stud Road
Knoxfield VIC 3180
Product Manufacturer: Karndean
Product Description: Art Select Oak Premier

Test conducted according to: AS 4586:2013 Appendix A
Location: Slip Check Pty Ltd Test Facilities, Melbourne VIC 3000
Conducted by: Nasser Cura

Date: 27 June 2016 Temperature: 18°C
Sample: Unfixed Cleaning: None
Rubber slider used: Slider 96 Conditioned: Grade P 400 paper dry followed by wet lapping film
Slope of specimen: Tested on a flat level surface
Direction of Test: Parallel to grain

	Specimen 1	Specimen 2	Specimen 3	Specimen 4	Specimen 5
Mean BPN of last 3 swings:	22	19	21	19	19

Reported SRV of Sample:	20
Class:	P2




Ryan Voorderhake
Technician