

## **Slip Check to AS 4586:2013**

### **Van Gogh**

NATA Accreditation Number 17139

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Accredited for compliance with ISO/IEC 17025

NATA is a signatory to the APLAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration and inspection reports

21 June 2016

## Test Report No. M0187

### Slip Resistance Classification of New Pedestrian Surface Materials

AS 4586:2013 Appendix A (Wet Pendulum Test)

The slip resistance Classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface.


Requested by: Kardean Designflooring  
Client Address: 835 Stud Road  
Knoxfield VIC 3180  
Product Manufacturer: Kardean  
Product Description: Van Gogh

Test conducted according to: AS 4586:2013 Appendix A  
Location: Slip Check Pty Ltd Test Facilities, Melbourne VIC 3000  
Conducted by: Nasser Cura

Date: 21 June 2016      Temperature: 19°C  
Sample: Unfixed      Cleaning: None  
Rubber slider used: Slider 96      Conditioned: Grade P 400 paper dry followed  
Slope of specimen: Tested on a flat level surface      by wet lapping film  
Direction of Test: Parallel to grain

	Specimen 1	Specimen 2	Specimen 3	Specimen 4	Specimen 5
Mean BPN of last 3 swings:	33	33	30	27	35

<b>Reported SRV of Sample:</b>	<b>32</b>
<b>Class:</b>	<b>P2</b>



Martin Daniel  
Materials Scientist